



Pollution Control Board:: Assam Bamunimaidam; Guwahati-21

(Department of Environment & Forests :: Government of Assam)

Phone: 0361-2652774 & 2550258; Fax: 0361-2550259

Website: www.pcbassam.org



No. WB/GUW/T-4348/21-22/12

Dated Guwahati, the 12th Jan. 2022

"CONSENT TO ESTABLISH"

"CONSENT TO Establish" (CTE) under Section 25 of Water (Prevention & Control of Pollution) Act, 1974 as amended and Rules Framed thereunder is granted to:

- i) Name of unit : Nalbari Medical College & Hospital
- ii) Name of the Occupier / : Anup Kr. Barman, Director of Medical
Applicant and Designation Education
- iii) Address of unit : Barigaon, Kundar Gaon, Dist. Nalbari
(Assam), Pin:-781335
- iv) Cost of the project : 39831.22 Lakhs
- v) Details of capacity:

Sl. No.	Unit	Capacity
1.	Hospital	500 bedded

TERMS AND CONDITIONS:

1. This CTE has been accorded based on the particulars furnished by the applicant vide Application ID: 155597 and subject to addition of further or more conditions if so warranted by subsequent developments. The CTE will automatically become invalid if any change or alteration or deviation is made in actual practice.
2. "CONSENT TO ESTABLISH" will be valid till the date of commissioning of the unit or seven (7) years whichever is earlier.
3. This CTE does not authorize for any expansion or modernization without prior permission of the Board.
4. This CTE may be modified, suspended or revoked by the Board in whole or in part during its term for cause including, but not limited to the following:-
 - a) Violation of any Terms and Conditions of this Consent;
 - b) Obtaining the Consent by misrepresentation or failure to disclose fully all relevant facts;
 - c) A change in any condition that requires temporary or permanent reduction or elimination of the authorized discharge/emission.
5. The project proponent must develop a greenbelt/plantation area with native trees only at least 33% of the total plot area to develop Greenbelt and Carbon Sink

Contd...p/2

15/12/21



As per the provisions of the Water (Prevention and Control of Pollution) Act, 1974 as amended and the Air (Prevention and Control of Pollution) Act, 1981 as amended that any Officer empowered by the Board on its behalf shall have without interruption, the right at any time to enter the hospital for inspection, collection of sample for analysis and may call for any information as deemed necessary. Denial this right will cause withdrawal of the Consent Order.

7. **The project Authority should install a display Board as per the Board's Notification No. PCBA/AGI-95/20-21/Notification/01 dtd.11.11.2021. (Appendix-A).**
8. Permission shall be obtained from the Central Ground Water Authority (CGWA) for the extraction of ground water.
9. It shall be the prime responsibility of the hospital management that the nearby population shall not be affected due to emission/effluent emanating out of the hospital.

Specific Conditions:

A) Air Aspect:

1. The industry must comply the National Ambient Air Quality Standards as per Schedule – VII under Rule, 3 (3B) of the Environment (Protection) Rules, 1986 as prescribed vide CPCB Notification No. B-29016/20/90/PCI-I dtd. 18.11.2009 (copy enclosed as **Annexure-B**), especially for $PM_{2.5}$ & PM_{10} .
2. The industry shall take adequate measures for control of noise from its own sources so as to bring the noise within the prescribed limit as stipulated below, as per GSR 7, dated Dec.22, 1998

Limit in dB (A) Leq	
Day Time (6:00am-10:00pm)	Night Time (10:00pm-6:00am)
50	40

B) Water Aspects:

1. Sewage Treatment Plant (STP) & Effluent Treatment Plant (ETP) shall be installed. The Health care facility shall disinfect the trade effluent with 1% Sodium Hypo-Chloride solution before taking it into Effluent Treatment System so as to kill the pathogens.
2. There shall be no direct discharge of sewage (waste water from bathroom, laundry, kitchen, etc.) and trade effluents (wash water from laboratories, labour rooms, operation theaters, etc.) into the nearby stream or land under any circumstances.
3. Storm water should not be mixed with the trade effluent.
4. The unit shall comply with the industry specific standards prescribed vide Rule 8 of the Bio-medical Waste Management Rules, 2016 for discharge of effluent as mentioned below:-

<u>PARAMETERS</u>	<u>PERMISSIBLE LIMITS</u>
pH	6.5 – 9.0
Total Suspended solids	100 mg/l
Oil and grease	10 mg/l
BOD	30 mg/l
COD	250 mg/l
Bio-assay test	90% survival of fish after 96 hours in 100% effluent.



C) Solid Waste Aspects:

1. Adequate facility should be created for collection, storage, transportation, treatment & disposal of non-hazardous industrial solid waste generated from the Industry.
2. Adequate system should be adopted on reduction of waste generation and enhancement of re-utilization & recycling of waste materials.
3. Burning of solid waste (garbage, dry leaves, paper, etc.) within the premises is strictly prohibited.
4. The unit shall strictly comply with all the provisions of the Solid Waste Management Rules, 2016.

D) Plastic Waste Aspects:

1. Plastic Waste generated in the unit shall be disposed of in accordance of the provisions under Plastic Waste Management Rules, 2016.
2. The unit shall submit the Annual Report under the Plastic Waste Management Rules, 2016 within 30th June every year.
3. The unit shall apply for Registration in Form-I under the Plastic Waste Management Rules, 2016 within One (1) month from the date of issue of this order, if applicable.

E) E-Waste Aspects:

1. Electronic wastes generated in the unit shall be disposed of as per the provisions of E-Waste Management Rules, 2016. The unit shall submit the Annual Report in the Form-III within 30th June every year.

F) Hazardous Waste Aspects:

1. The unit shall apply for authorization under Hazardous & Other waste (Management & Trans-boundary Movement) Rules, 2016.
2. Adequate facilities shall be provided for collection and storage of spent oil, waste oil etc. All the Hazardous wastes shall be sent to registered recyclers for recycling. The unit shall maintain a separate register for recording details such as generation, name of the recycler/re-processor etc. to whom sold etc.
3. Appropriate facility should be created for handling, storage, treatment & disposal of Hazardous waste generated from the industry in accordance to the provisions of the Hazardous & Other Waste (Management & Trans-boundary Movement) Rules, 2016 including Notification, Guidelines issued there under;
4. The unit should submit the annual return under Hazardous & Other Waste (Management & Trans-boundary Movement) Rules, 2016 in the Form-IV within 30th June every year.

G) Bio-medical Waste Management:

1. The authority shall have to manage the Bio-medical Waste generated from the unit as per the Bio-medical Waste Management Rules, 2016 and subsequent amendments and to ensure that such waste do not mix with the general solid waste. The Conditions mentioned in APPENDIX-C shall be fully adhered to.

Contd...p/4



-4-

The unit shall submit compliance report of the mandated conditions of this CTE by April 15, every year to the Member Secretary, PCBA as well as to Regional Office, Guwahati-II, PCBA. The Board will have the liberty to withdraw the CTE if adequate pollution control and safety measures are not taken.

(Shantanu Kr. Dutta)

Member Secretary

Dated Guwahati, the 12th Jan, 2022

Memo No. WB/GUW/T-4348/21-22/12 -A,
Copy to: 1585

1. M/s Nalbari Medical College & Hospital, Barigaon, Kundar Gaon, Dist. Nalbari (Assam) - for information & necessary action.

153245
(Shantanu Kr. Dutta)

Member Secretary